


Electrifying Existing Buildings for Health & Equity

Shayna Hirshfield-Gold Climate Program Manager, City of Oakland



Equitable Electrification

- Replacing gas appliances with efficient electric alternatives
 = health + safety + justice
- Gas = toxic, flammable, explosive
- Justice = Affordability, energy reliability (solar + storage), related upgrades, JOBS
- Efficiency reduces energy bills, upgrade costs, & grid stress



Key Challenges

- Housing costs
- Utility costs
- Education & awareness
- Old infrastructure
- Ensuring access
- Added complexity:
 - Restaurants
 - Affordable housing



Major Opportunities

- Clean grid... & getting cleaner!
- EBCE, BayREN, Switch is On, IRA (Rebates, Incentives, Info)
- Workforce development
- Electrification + Resilience
- Ripe technologies and Statewide momentum



Oakland Timeline

- All-electric new construction (Dec. 2020... the first step)
- Workforce Focus (2021-23)
- Continued Engagement (ongoing)
- Existing Building Electrification Roadmap (Summer 2023)
- Major Renovations (2023?)
- All buildings all electric: 2040






Electrification in San Francisco

Barry Hooper | September 28, 2022




Emissions from San Francisco Buildings





Gas in the Bay Area






Source: Bay Area Air Quality Management District

Natural gas impacts . . .











Health

Safety

Resilience


Equity



Today's Focus: Existing Multifamily and Commercial



- Electrification = opportunity
- Smart use of existing electric service can mean
 - Faster, Simpler Projects
 - Lower Cost
 - Comfort and Performance
- When upgrading electric service
 - Process
 - Timing
 - Cost



Inflation Reduction Act - Commercial



Commercial Building Energy Efficiency Tax Deduction (179D)

Site EUI Reduction	Without Prevailing Wage	With Prevailing Wage & Apprenticeship
Minimum 25%	\$0.50 / square foot	\$2.50 / square foot
Each added 1%	\$0.02 / square foot	\$0.10 / square foot
Cap: 50%	\$1.00 / square foot	\$5.00 / square foot

AND

- Solar Investment Tax Credit (25D): 30% on PV and battery storage or
- new Production Tax Credit (PTC): \$0.026/kWh for 10 years
- Commercial and fleet electric vehicle tax credit: \$7,500/vehicle

Secondary Network Limitations

Big Impacts

Simplified. Consult your tax professional for details.

Inflation Reduction Act - Multifamily



Program	Key Features	When Available
Energy Efficient Home Credit	30% tax credit Does not affect LIHTC basis Available to multifamily owners	Starts 2023
HOMES Rebates	Rebate program based on projected energy savings Rebate amount is increased for measured energy savings and for low- and moderate-income Range: \$2,000 to \$8,000 – capped at 50% of project cost	Expected mid-2023
High-Efficiency Electric Home Rebate Program (HEERA)	Up front rebates (point of sale) Income-qualified: • Up to 100% of project cost for <80% AMI • Up to 50% for households 80% to 150% AMI	Expected mid-2023
Solar Investment Tax Credit	30% on PV and battery storage	Now

Simplified. Consult your tax professional for details.



Navigating Multifamily

Electrical Constraints

Bringing the benefits of clean energy & energy efficiency to underserved & communities

John NealDirector of Technical Services,
AEA West

ineal@aeacleanenergy.org

Contambor 2002



MF Electrification Hurdles

- Electrical capacity is often limited
- Electrical upgrades can be expensive, time consuming, or invasive
- How difficult is it to electrify these electric loads*?
 - DHW (easier)
 - Heating (moderate)
 - Dryers (moderate)
 - Cooking (difficult)

*Newer buildings, buildings with cooling, and buildings with existing electric cooking are much easier to electrify





Working with Existing Capacity

Right size

- Contractor or engineer must size equipment*
- Do not match existing
- Factor in envelope and distribution improvements

Not enough electrical capacity?

- Increase equipment efficiency, further reduce loads
- •Eliminate or reduce electric resistance (DHW)
- Reduce or eliminate redundancy
- Require conversation between electrical, mechanical engineers and contractor to understand impacts and opportunities.



*HVAC - Using load calculation tools such as Wrightsoft, CBECC, EnergyPro, Manual J, IES DHW – Use <u>Ecosizer</u>, manufacturer tools, and/or monitored existing load.

Example Electric Load Impacts

Space Heating	Electric Load Sizing Impact
Mini split single zone (1 ton)	1200 W
Mini split multi zone (3 ton)	4,000 W
Central (3 ton)	5,500 W
Central (3 ton) with electric resistance	10,300 W

Water Heating	Electric Load Sizing Impact
Low Power 120V model	900W
240V 15 Amp Hybrid	2300W
Split Heat Pump	3120W
Standard 240V 30Amp Hybrid	4500W













Cooking

Electrification usually triggers electrical upgrades

- First, engage aggressive electrical engineer to look at all pathways
- Plan for electrical upgrades

If stuck, alternate solutions:

- (Future) low amp induction stove
- Induction cooktop only with countertop plug in oven or combination microwave/convection oven: **turkey dilemma.**

Ensuring success:

- We must deliver an excellent cooking experience! USE INDUCTION.
- Provide training, pot/pan/gift card to help with transition.

Cooking	Electric Load (Sizing Impact)
2 burner induction	1800W
Cooktop	3000W
Wall Oven	3400W
Induction Range	9600W





Navigating Electrical Load Calcs

- NEC Deemed Calc: Default approach, Conservative
 - Uses combination of actual and deemed values, and demand factors to calculate capacity
 - Various exceptions and "levers" can be adjusted by engineer
- NEC Load Monitoring Study: Generous
 - Uses actual peak energy use to calculate whether new loads can be added
 - 30-day study using power meter or 1-year of monthly peak-demand recordings
 - 30-day study must include time period of highest usage
 - Meter where potential infrastructure limitations exists (pinch points)
 - If limitation is at unit level, confirm if monitoring a sample of units is acceptable by (CBO and Electrical engineer)
- Above are used for AHJ permitting and discussions with utility (when service upgrades are required). Utility engineers may perform their own internal calculation.



Electrical Capacity Results

Still not possible to go all electric with existing service?

- Checked all reasonable pathways to make project feasible such as:
 - Combining low amperage equipment, efficiency measures, and electric load monitoring
 - Move from central heating to in unit or vice versa?
- Are default values being used in calculations? Validate.

If a service upgrade is needed

- Utility cost, timelines, and scope are often assumed to be the worst case by project team before having a conversation. Don't let this kill the project.
- Talk to utility early and plan on submitting an all-electric design for their review to understand implications.
- Do partial electrification now



Project Development Approach


- 1. Define initial goals for project
- 2. Identity potential funding
- 3. Recruit the right team, with experience appropriate to the scale and complexity of project
- 4. Have team work together to identify critical decision points and dependencies
- 5. Engage with utility early to discuss project
- 6. Refine project scope and specifications within bounds of goals
- Initiate project with flexibility!
- 8. Complete project
- 9. Monitor performance





Recruit the right team

- Contractor and other design professionals should be interested
- Problem solvers, collaborators, and creative thinkers are necessary
- Prior experience and references encouraged
- Bring on engineers for larger or more complicated projects
- Understand each person's role and level of expertise
- Team must work together at each step





Full Electrification Example

- Corona, CA | Built 1960s
- (40) Four-plexes (each apt is two bed)
- Central gas DHW
- In unit gas furnaces and ranges
- Each building has pole drop, units and common meter each have a 40 amp service
- Goal of full electrification during rehab, could upgrading existing 40 amp apt services be avoided?







		2 Ton Ductless HP			
		Central DHW			
		Central DillV			
		Basis of Design			
General Load					
	receptacle and lights	3120			
	kitchen appliance circuits	1500			
	1st 3KVA @100%	3000			
	Remainder at 35%	567			
	Total	3567			
HVAC + DHW	Load				
	HVAC	6630			
	HPWH	0			
	1st 8KVA at 100%	6630			
	Remainder at 40%	0030			
Annlianess	Remainder at 40%	U			
Appliances		4200			
	garbage disposal	1200			
	dishwasher	1200			
	microwave	1000			
	total w/ 75% demand factor	2550			
Cooking					
	electric range/induction cooktop	5000			
	80% demand factor	4000			
Total	VA	16,747	12,322	10,057	8,422
	Total Amps	70			









		2 Ton Ductless HP	2 Ton Ductless HP		
		In Unit HPWH	Central DHW		
General Loa	nds		Basis of Design		
	receptacle and lights	3120	3120		
	kitchen appliance circuits	1500	1500		
	1st 3KVA @100%	3000	3000		
	Remainder at 35%	567	567		
	Total	3567	3567		
HVAC + DH	W Load				
	HVAC	6630	6630		
	HPWH	1980	0		
	1st 8KVA at 100%	8000	6630		
	Remainder at 40%	610	0		
Appliances					
	garbage disposal	540	1200		
	dishwasher	1200	1200		
	microwave	1000	1000		
	total w/ 75% demand factor	2550	2550		
Cooking					
	electric range/induction cooktop	5000	5000		
	80% demand factor	4000	4000		
Total	VA	17,622	16,747	10,057	8,422
	Total Amps	73	70		









		2 Ton Ductless HP	2 Ton Ductless HP	1 Ton Ducted HP		
		In Unit HPWH	Central DHW	Central DHW		
General Loa	ds		Basis of Design			
	receptacle and lights	3120	3120	3120		
	· •					
	kitchen appliance circuits	1500				
	1st 3KVA @100%	3000				
	Remainder at 35%	567	567	567		
	Total	3567	3567	3567		
HVAC + DHV	V Load					
	HVAC	6630	6630	2700		
	HPWH	1980	0			
	1st 8KVA at 100%	8000	6630	2700		
	Remainder at 40%	610	0	0		
Appliances						
	garbage disposal	540	1200	540		
	dishwasher	1200	1200	1200		
	microwave	1000	1000	1000		
	total w/ 75% demand factor	2550	2550	2055		
Cooking						
	electric range/induction cooktop	5000	5000	5000		
	80% demand factor	4000	4000	4000		
Total	VA	17,622	16,747	12,322	10,057	8,422
	Total Amps	73	70	51		









		2 Ton Ductless HP	2 Ton Ductless HP	1 Ton Ducted HP	Low Load HP	
		In Unit HPWH	Central DHW	Central DHW	Central DHW	
					+ Aggressive	
General Loa	ds		Basis of Design		Cooking	
	receptacle and lights	3120	3120	3120	3120	
	kitchen appliance circuits	1500	1500	1500	1500	
	1st 3KVA @100%	3000	3000	3000	3000	
	Remainder at 35%	567	567	567	567	
	Total	3567	3567	3567	3567	
HVAC + DHV	V Load					
	HVAC	6630	6630	2700	1635	
	HPWH	1980	0		0	
	1st 8KVA at 100%	8000	6630	2700	1635	
	Remainder at 40%	610	0	0	0	
Appliances						
	garbage disposal	540	1200	540	540	
	dishwasher	1200	1200	1200	1200	
	microwave	1000	1000	1000	1000	
	total w/ 75% demand factor	2550	2550	2055	2055	
Cooking						
	electric range/induction cooktop	5000	5000	5000	3500	
	80% demand factor	4000	4000	4000	2800	
Total	VA	17,622	16,747	12,322	10,057	8,422
	Total Amps	73	70	51	42	









	2 Ton Ductless HP In Unit HPWH	2 Ton Ductless HP Central DHW Basis of Design	1 Ton Ducted HP Central DHW	Low Load HP Central DHW + Aggressive Cooking	Central Heat Central DHW + Aggressive Cooking
General Loads	2426	,	2422	•	_
receptacle and lights	3120			3120	3120
kitchen appliance circuits	1500			1500	
1st 3KVA @100%	3000			3000	
Remainder at 35%	567	567	567	567	567
Total	3567	3567	3567	3567	3567
HVAC + DHW Load					
HVAC	6630	6630	2700	1635	0
HPWH	1980	0		0	0
1st 8KVA at 100%	8000	6630	2700	1635	0
Remainder at 40%	610	0	0	0	0
Appliances					
garbage disposal	540	1200	540	540	540
dishwasher	1200	1200	1200	1200	1200
microwave	1000	1000	1000	1000	1000
total w/ 75% demand factor	2550	2550	2055	2055	2055
Cooking					
electric range/induction cookt	op 5000	5000	5000	3500	3500
80% demand factor	4000	4000	4000	2800	2800
Total	VA 17,622	16,747	12,322	10,057	8,422
Total	Amps 73	70	51	42	35

- No scenarios triggered utility service upgrades
- Last two scenarios were viable but not desirable
- Final scope will require upgrading unit feeder and sub panel to accommodate electric cooking



Incentives for Multifamily Electrification

NOW/SOON











































































Existing Commercial Buildings

Barry Hooper September 28, 2022



Decarbonization framework for Existing Buildings




LEVERAGE EXISTING POLICIES

- Energy benchmarking
- 100% Renewable Electricity

NEW

- Require a Plan for Decarbonization
- Require decarbonization by 2035 and regular progress reports
- Flexibility: Invest fees in decarbonization of low-income and affordable housing



Energy Code



California's codes are evolving to better support efficient electrification

and

Cities cannot waive Title 24.

Efficiency requirements apply.

Electric resistance boilers are not the solution.







Efficient Electrification



SPUR Urban Center

14,500 sq ft building

188 Embarcadero

99,625 sq ft building

Levi's Plaza

867,000 sq ft, 6 buildings

Empire Building Challenge

131 Buildings, 10 Owners, 52M sq ft

SFO Central Plant

3.3M sq ft, 4 terminals

More Examples: <u>electrifiedbuildings.org</u>



Small Office



SPUR Urban Center

14,500 sq ft office, 4 stories

- Existing conditions
 - Efficient, and room to improve
 - Space conditioning: rooftop AC units with gas burners (only use of gas)
- Decarbonization plan
 - Specify heat pumps when rooftop HVAC units are replaced.
- Implications
 - No change to electric peak: no change to electric service
 - Can qualify for over-the-counter building permits
 - Similar cost to like-for-like

More Info: <u>spur.org/news/2022-08-31/spurs-plan-decarbonize-urban-center</u>



Medium Office



188 The Embarcadero

99,625 sq ft office, 7 stories

- Existing conditions
 - Efficient, regularly ENERGY STAR
 - Gas uses: Hydronic boiler (reheat) and SHW/DHW
- Piloted Strategic Decarbonization Assessment
 - Defined the cost of inaction
 - Owner set decarbonization goal; communication was key
- Outcomes
 - Upgraded HW and heating to heat pumps
 - No change to electric service
 - Having a plan facilitated action

Thanks: Google



Office Campus




Levi's Plaza / 867,000 sq ft office

- Existing conditions
 - Built 1981, purchased 2019, zero by 2025
 - Typical office: chillers, cooling towers, AHUs, gas fired boilers with VAC reheat at zone/floor
- Challenges in first 2 buildings
 - Space: An air-source heat pump is larger than a boiler
 - Supply water temp: VAVs required adjustment
 - Electric capacity: Efficiency allowed re-distribution of existing power to meet changes in load
- Outcomes
 - Transition required integrated design
 - No change to electric service
 - Phased installation completed while occupied

Thanks: Jamestown Properties

More Info: casestudies.uli.org/all-case-studies/



Very Large Office



345 Hudson St / 100 Ave of the Americas, NYC

978,277 sq ft / 376,965 sq ft

- Existing conditions
 - Built in 1930s; hot summers and cold winters
 - Fully occupied
 - Steam heating, PTAC cooling
- Challenges: Space for heat pumps, Electric service
- Solutions:
 - Floor-by-floor water-source heat pump
 - Dedicated outside air energy recovery ventilation
 - Dynamic thermal storage
- Outcomes: Reduced heating, cooling and electric use by recycling heat from space to space in the building.

Thanks to: NYSERDA Empire Building Challenge

Empire Building Playbook: knowledge.nyserda.ny.gov/display/EBP



Emerging Practice for Heating Hot Water



Evaluate "How low can it go?"

1. Best Case Scenario

- 120F to 110F supply
- Single stage air source heat pump

2. Minimum operational change


- 175F supply
- 2-stage ASHP and WSHP

3. Happy Medium

- 160F supply
- Single stage ASHP low-GWP

4. Major System Replacement

- Highest efficiency
- 100 to 110F supply




Thanks: SmithGroup

More Info: collaborativedesign.org; redwoodenergy.net/research/

Summary



- Electrification = opportunity
- Assess and plan
- Efficient optimization of existing electric service can mean
 - Faster, less complex projects
 - Lower cost
 - Improved performance
- Electric service must sometimes be upgraded



Thank You



Barry Hooper, Senior Green Building Coordinator barry.hooper@sfgov.org

Previously: September 7 –

Electric Service Optimization for Existing Single Family:

https://www.youtube.com/watch?v=Tv bccFGT2Q

Or visit City of Oakland's YouTube channel



SF Environment All Rights Reserved

The author of this document has secured the necessary permission to use all the images depicted in this presentation. Permission to reuse or repurpose the graphics in this document should not be assumed nor is it transferable for any other use. Please do not reproduce or broadcast any content from this document without written permission from the holder of copyright.



Meeting Agenda

Date/Time:	September 28 th , 2022 at 10 am-12 pm			
Location:	Teams (Virtual)	Recorder	Hannah Kaye	
Desired Outcomes:	Desired Outcomes: 1. Webinar attendees are informed of PG&E's Added Load process.			
Number	Agenda Item(s)			
1	Introductions			
2	Building and transportation electrification			
3	Impacts of electrification on primary and secondary distribution			
4	Primary trigger of electric service upgrades			
5	Added Load process and timeline			
6	Helpful resources			
7	Wrap up			



Building and Transportation Electrification

Transportation Electrification



100% zero emission passenger vehicle sales by 2035



100% zero emission drayage truck operations by 2035



100% zero emission from onroad medium and heavy-duty vehicles by 2045

Building Electrification



California Air Resources
Board approved a plan to ban
sale of gas water and space
heating appliances by 2030



25+ cities in PG&E's territory are considering electrification retrofit targets



California Energy Commission recommended a goal of 6 million heat pumps by 2030




Impacts of Electrification on Primary and Secondary Distribution

Commercial and large multifamily building electrification projects can trigger primary and secondary system upgrades, particularly when installing EV charging. PG&E is preparing for the anticipated impacts of electrification on the electric grid by improving grid planning.

<u>Primary lines:</u> higher-voltage lines located at the top of utility poles, above transformers. Voltages range from 4,12,21,34kV (in select areas).

<u>Secondary lines:</u> lower voltage lines are below transformers. Typical secondary voltages range between 120, to 480 volts.






Primary Triggers of Electric Service Upgrades

Customers upsizing their main switch gear (i.e., electric panel) or termination section is the primary cause of service upgrades.

Multi-family Switchgear Equipment Commercial Switchgear Equipment







Stages of Added Load Process

- 1. Customer planning and application
- 2. Load assessment and/or service design
- 3. Contract and payment
- 4. Construction and energization



Added Load Process: Customer Planning and Application


PG&E Responsibility: None

Applicant Responsibility: Acquire contractor and determine electrification needs

Timeline: Dependent on applicant

Utility-Owned and Customer-Owned Electric Equipment

For Residential Service to Single-Family Dwellings and Duplexes



PG&E Infrastructure	Customer Infrastructure	
Front-of-the-meter (FTM)	Behind-the-meter (BTM)	
PG&E owns and is responsible for constructing, maintaining, and upgrading electrical infrastructure to the meter panel	Customer owns and is responsible for constructing, maintaining, and upgrading infrastructure from meter to the customer appliances	




Added Load Process: Customer Planning and Application

PG&E Responsibility: Contact applicant within ~ 3 days and confirm application details

Applicant Responsibility: Submit an Added Load application on YourProjects.pge.com

Timeline: Applicant Dependent. PG&E will respond within ~ 3 days of application submission

Helpful Links: Application User Guide



Documentation/Information	Type of Documentation	Required?
Picture of electric panel label	Pictures	Required
Picture of the meter number	Pictures	Required
Picture of the main breaker	Pictures	Required
Picture of the electric panel - 6 feet on both sides - 6 feet in front - Include picture of weatherhead	Pictures	Required
Picture of area where new electric panel will be relocated if moving (mark the location on the picture)	Pictures	Required
Picture of service wire where it runs over the job site / neighboring property	Pictures	Required
Picture of where the service wire is attached to the PG&E pole / wire	Pictures	Required
List of new electric appliances and associated new loads (e.g., HVAC tons, wattage, etc.)	Spreadsheet (see next tab)	Required

^{*} Applicable to Overhead Service Only



Added Load Process: Load Assessment and/or Service Design

PG&E Responsibility: Perform Load Assessment and inform applicant of findings

Applicant Responsibility: Pay Engineering advance and support PG&E representative with

additional project details as needed

Timeline: ~ 90-180 days


Helpful Links: Make Payments Online

Engineering Advance

- Covers the cost for PG&E to perform load assessments
- \$2,500 (subject to change)
- May be refunded in like for like panel replacements

Relevant Infrastructure	Capacity	
Service wire or cable (if underground)		
Secondary Conductors	Your PG&E representative will determine existing capacities for this infrastructure.	
Transformers		
Primary Conductors (depending on size of load)		

Utility-Owned and Customer-Owned Electric Equipment For Residential Service to Single-Family Dwellings and Duplexes





Added Load Process: Adding New Load through Building Electrification

Type of Building	Pre-Electrification	Post-Electrification
10-unit Multifamily Building w/ gas water and space heating, cooking	5 kVA per living unit	8-10 KVA per living unit
Commercial Kitchen w/ gas cooking	7-10 kVA	25-35 kVA

^{*}Illustrative Example



Added Load Process: Adding New Load through Transportation Electrification

Details	Multifamily Building	Commercial Building	
Location	Oakland	Bay Area	
Number of chargers	~100 L2 (7.2 kW) charging ports	~30 L2 (7.2 kW) charging ports	
Total Incremental load	720 KW	216 KW	
Necessary upgrades	meter, panel, switch gear, transformer upgrade	meter, panel, switch gear, new additional transformer, and upstream 3 phase switch	



Added Load Process: Contract and Payment

PG&E Responsibility: Complete estimating, design and send final contract

Applicant Responsibility: Sign contract and pay for any necessary customer costs

Timeline: ~180 days

Helpful Tip: A detailed added load application can expedite the process



PG&E coordinates a site visit with customer to assess the scope of the project

PG&E designs and estimates necessary service work to send to customer

Customer signs contract with PG&E and pays for any necessary costs

* EA is applied to final contract cost



Added Load Process: Contract and Payment

PG&E Responsibility: None

Applicant Responsibility: Sign contact and complete payment

Timeline: Dependent on applicant payment timeline

Electric Rule 15 and 16 govern the allowance for service upgrades

- Residential applicant is responsible to pay all upfront costs associated with service installation and an allowance of \$3,255 per meter will be applied to the refundable portion of costs
- Non-residential applicants receive an allowance based on their expected usage once connected

The top variables that impact cost

- Panel location and its distance from the nearest distribution point
- Transformer (if a single customer is on a transformer)
- If service is underground (trenching costs)

Types of customer costs

 Customer costs include any necessary trenching, substructure/conduit installation new service conductor, and protective structure.







Added Load Process: Construction and Energization

PG&E Responsibility: Complete service installation and any applicable distribution betterment work

Applicant Responsibility: Complete projects and required inspections

Timeline: ~1.5 – 3 months for PG&E work

Preconstruction Meeting

Customer Construction

Service Installation and **Energization**











PG&E coordinates meeting to align on customer and utility tasks and coordinate inspections

Customer completes
substructure (if
underground) installation
and inspections (e.g.,
Green Tag inspection)

PG&E installs new service and coordinates disconnect/reconnect while customer completes panel upgrade



Gas Disconnection Process When All-Electric

Once your building has converted from dual fuel to all-electric, you can safely stop gas services and gas interconnection charges by applying to modify your existing services

Log in to the *PG&E Your Projects* portal>Start New Application>Select **New Electric or Gas Services or Change to an existing Electric or Gas Service**



1. Why stop gas services?

- <u>Safety:</u> eliminate safety concerns during an accidental dig-in or other damage.
- <u>Customer cost savings:</u> customers pay a \$0.13151/day minimum transportation charge to remain connected to the gas system.

2. Who pays for removing gas system?

Any gas service greater than 10 years will be removed at PG&E's expense



Helpful Resources & Wrap Up

- 1. Pacific Energy Center Classes (www.pge.com/energyclasses)
- 2. Induction Loaner program (www.pge.com/inductionloaner)

Thank you

Khalil Johnson: Khalil.Johnson@pge.com

Nick Souza: Nick.Souza@pge.com

